

Product Certification Schedule

Schedule No.	205/001/003
Test Report No.	H9TTA750, H9TTL750 & H10TTA750
Prev. Schedule No.	Not applicable
Licensee:	IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND
Factory:	IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND
Specification	BS EN 50525-3-41:2011 - Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 3-41: Cables with special fire performance - Single core non-sheathed cables with halogen-free crosslinked insulation, and low emission of smoke
Type of Cable	Heat resistant cables (90oC) Clause 4.2 - Cables for fixed wiring - H07Z-K Table B.2 - Cables with flexible conductor (450/750 V)
HAR Document	EN 50525-3-41:2011
HAR Specification	H07Z-K
Range of Approval	1.5sqmm to 10sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 5 conductor. Insulation - EI5.
Origin Thread	Not Applicable
Origin Mark	IDH CABLES

PERMISSIBLE MARKS



BASEC ◁ HAR ▷

BLACK - 1cm
RED - 1cm
YELLOW - 3cm
THREAD

Note: The black - red - yellow thread has been registered in this country as an identification thread in the BSI "Register of colours of manufacturers' threads for electric cables and cords" for Verband Deutscher Elektrotechniker (VDE) e.V., Frankfurt, Germany. VDE has authorized BASEC to use this thread.

Please refer the BASEC Product Certification Requirements

Expiry Date: 19/02/2018

This certificate is issued according to the rules of the HAR agreement, wherein the certificate issued by any certification body adhering to the HAR agreement has the same worth and validity in all the other certification bodies' countries. This licence demonstrates the conformity with the essential requirements of the Directive 2006/95/EC (LVD)

Signed for and on behalf of the British Approvals Service for Cables

Date 14/05/2015

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004

BSF060.002/A1750