

## Product Certification Schedule

Schedule No: 205/001/002

Licensee: IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND

Factory: IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND

Specification: BS 7211:2012 - Electric cables - Thermosetting insulated and thermoplastic sheathed cables for voltages up to and including 450/750 V, for electric power and lighting and having low emission of smoke and corrosive gases when affected by fire

Type of Cable: Table 5 - Thermosetting insulated, single-core 6241B, flat twin 6242B and flat 3-core 6243B sheathed cables with circuit protective conductor (CPC), 300/500 V

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1sqmm to 1.5sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 1 conductor. 1sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive. Flat twin to 3-core inclusive. Class 1 conductor. 1sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Flat twin. Class 2 conductor (Including strip easy type). 4sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Flat 3-core. Class 2 conductor. Sheath - LTS2. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: IDH CABLES

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 19/02/2018

Signed for and on behalf of the British Approvals Service for Cables

 Date 02/04/2015

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004