

Product Certification Schedule

Schedule No: 205/001/029

Licensee: IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND

Factory: IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND

Specification: BS 7629-1:2015 Electric Cables - Specification for 300/500 V fire resistant, screened, fixed installation cables having low emission of smoke and corrosive gases when affected by fire. Part 1: Multicore cables

Type of Cable: Table 2 Dimensions of 2-core, 3-core and 4-core cables.

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive. 2-core to 4-core inclusive. ENHANCED 120. Additionally tested to BS 6387 Categories C, W & Z. Sheath - LTS3. Insulation - EI2

Origin Thread: Not Applicable

Origin Mark: IDH CABLES KILFLAM ENHANCED 3000

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 19/02/2018

Signed for and on behalf of the British Approvals Service for Cables

Date 21/12/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004