



BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No: 205/001/024
Licensee: IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND
Factory: IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND
Specification: BS 8436:2011 Electric Cables - Specification for 300/500V screened electric cables having low emission of smoke and corrosive gases when affected by fire, for use in walls, partitions and building voids - Multicore cables
Type of Cable: Table 1 Dimensions of cables
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.0sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. 2-core to 4-core inclusive. Sheath - LTS3. Insulation - GP8.
Origin Thread: Not Applicable
Origin Mark: IDH CABLES

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 19/02/2018

Signed for and on behalf of the British Approvals Service for Cables

Date 06/09/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

