

Product Certification Schedule

Schedule No: 205/001/019
Licensee: IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND
Factory: IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND
Specification: I.S. 273:1988 - Cables with polyvinyl chloride (PVC) or cross-linked polyethylene (XLPE) insulation 600/1000 V and 1900/3300 V with and without steel wire armour (SWA)
Type of Cable: Table 37 - Screened XLPE insulated multi-core 0.6/1kV cables with stranded or solid copper conductors
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.0sqmm to 6sqmm nominal cross-sectional area of conductors inclusive. 2-core to 4-core inclusive. Sheath - LTS3. Insulation - GP8.
Origin Thread: Not Applicable
Origin Mark: IDH CABLES

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 19/02/2018

Signed for and on behalf of the British Approvals Service for Cables

Date 29/10/2015

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004