

# BASEC

BRITISH APPROVALS SERVICE FOR CABLES

## Product Certification Schedule

Schedule No: 205/001/016  
Licensee: IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND,  
Factory: IDH CABLES LIMITED, MILLBANKS, NEW ROSS, COUNTY WEXFORD, IRELAND,  
Specification: I.S. 201-4:2013 - Polyvinyl Chloride Insulated Cables of rated voltages up to and including 450/750 V. Part 4: PVC and Low Smoke Halogen Free Sheathed cables for fixed wiring  
Type of Cable: Table 3 - PVC/PVC Twin-flat. Type IE-N05VVH2-U and IE-N05VVH2-R.  
HAR Document: Not applicable  
HAR Specification: Not applicable  
Range of Approval: 1.0sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Twin-flat. Sheath - Type 6. Insulation - T11.  
Origin Thread: Not Applicable  
Origin Mark: IDH CABLES

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 19/02/2018

Signed for and on behalf of the British Approvals Service for Cables

Date 27/05/2015

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004